

AMC TECH NEWS Jun. 2012/HSQE./05

PARIS AND TOKYO MOUs ON PORT STATE CONTROL WILL HOLD JOINT CONCENTRATED INSPECTION CAMPAIGN ON FIRE SAFETY SYSTEMS ARRANGEMENTS

The 43 Maritime Authorities of the Paris and the Tokyo Memoranda of Understanding (MoU) on Port State Control will launch a joint Concentrated Inspection Campaign (CIC) with the purpose to ensure compliance with SOLAS Chapter II-2/ Construction - fire protection, fire detection and fire extinction arrangements on board ships. This inspection campaign will be held for three months, commencing from 1 September 2012 and ending on 30 November 2012.

In practice, the CIC will mean that during a regular port State control inspection conducted under the regional ship selection criteria within the Paris and Tokyo MoU regions, the fire safety arrangements, maintenance records and other applicable documentation will be verified in more detail for compliance with SOLAS Chapter II-2.

Port State Control Officers (PSCOs) will use a list of 12 selected items to verify critical areas for the shipboard fire safety systems, some of which are related to documentation, equipment and crew familiarisation.

For this purpose, PSCOs will apply a questionnaire listing a number of items to be covered during the concentrated inspection. The questionnaire has been annexed to this press release.

When deficiencies are found, actions by the port State may vary from recording a deficiency and instructing the master to rectify it within a certain period to detaining the ship until serious deficiencies have been rectified.

In the case of detention, publication in the monthly detention lists of the Paris and Tokyo MoU web sites will take place.

It is expected that the Paris and Tokyo MoUs will carry out approximately 10,000 inspections during the CIC.

The results of the campaign will be analysed and findings will be presented to the governing bodies of the MoUs for submission to the IMO.

Other MOUs may also carry out a CIC on the same topic during this period.





CIC ON FIRE SAFETY SYSTEM (FSS)

Inspection Authority			
Ship Name		Flag	
IMO number		Classification Society	
Date of inspection		Inspection port	

No.	Item	Yes	No	N/A
1	Does the Fire Control Plan meet the requirements?	<input type="checkbox"/>	<input type="checkbox"/>	
2a	Do the fire fighters' outfits including personal equipment comply with the requirements?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2b	Do the Emergency Escape Breathing Devices (EEBD) comply with the requirements?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3	Are the portable extinguishers ready for use in locations as per the fire plan?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
*4	Does the test of automatic audible alarm sound prior to release of a fixed gas fire-extinguishing medium into spaces in which personnel normally work?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
*5a	Are the fire protection systems, fire fighting-systems and appliances maintained ready for use?	<input type="checkbox"/>	<input type="checkbox"/>	
5b	Is there a maintenance plan onboard to show that fire protection systems and fire-fighting systems and appliances (as appropriate) have been properly tested and inspected?	<input type="checkbox"/>	<input type="checkbox"/>	
*6	Is the crew familiar with the location and operation of fire-fighting systems and appliances that they may be called upon to use?	<input type="checkbox"/>	<input type="checkbox"/>	
7	Does the test of the sprinkler system trigger an automatic visual and audible alarm for the section?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
*8	Does the activation of any detector or manually operated call point initiate a visual and audible fire signal at the control panel on the bridge or control station?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
9	Is the lighting in escape routes, including the Low Location Lighting systems where applicable properly maintained?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
*10	Is the Emergency Fire pump, capable of producing at least two jets of water?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11	Are the Isolating valves of the fire main marked, maintained and easily operable?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
*12	Where a fire drill was witnessed was it found to be satisfactory?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13	Was the ship detained as a result of the CIC?	<input type="checkbox"/>	<input type="checkbox"/>	

Notes: If the box "No" is ticked off, for questions marked with an "*" the ship may be considered for detention. The detail of any deficiencies should be appropriately entered on the PSC Report of Inspection -Form B and include the deficiency code as indicated in the question.

For questions combined with the conjunction "and" if the box "YES" is checked that means all the parts in the question are in compliance.